



INSPECTION CERTIFICATE

File number **18.163.399-1**

Issued by inspection body No. 4002 accredited by CAI according to ČSN EN ISO/IEC 17020:2012:

inChaNet s.r.o.
Hasičská 3019, 756 61, Rožnov pod Radhoštěm, Czech Republic

On the basis of results conducted 4.2.2026, which are listed under Inspection report of TÜV SÜD Czech file No.: 18.163.399-2 and 18.163.397-1 we hereby confirm conformity of the below mentioned device:

Name:	CUBISH STREET
Serial number:	251500001
Power voltage:	3x 360 – 440 VAC
Frequency:	50/60 Hz
Input current max.:	3x63A or 1x63A
Output power:	22 kW, 3x32A or 1x32A max
Protection class:	Class I
Protect cover:	IP 65 body, IP44 plugs
IK protection class:	IK9(charger body except display)
Manufacturer:	inChaNet s.r.o.

With requirements:

ČSN EN IEC 61851-1 ed.3:2020+ Opr.1: 2024 (idt IEC 61851-1:2017), ČSN EN IEC 61851-21-2:2021 (idt IEC 61851-21-2:2018) and related standards, which are mentioned in Inspection Report no.18.163.399-2 and 18.163.397-1.

Valid conditions:

The outcomes of inspection presented in the inspection report are related only to the inspected device; the results are presented in Inspection Report 18.163.399-2 and 18.163.397-1.

In Vejprnice, on 4.2.2026



On behalf of TÜV SÜD Czech s.r.o. : **Petr Domša, Ph.D.**

v.z.